

# Mounting Release

## DICTATOR V 1600 Door Check on Fire Protection Doors

The following table lists all manufacturers and their fire protection doors on which the DICTATOR V 1600 door check may be mounted

- because it is part of the door approval
- or because we have a manufacturer's declaration for using the V 1600 door check on the respective door.

Please note that different models of the V 1600 are used on the respective doors. The exact model designation is to be found in the column "V 1600 model".

Please also note that using a mounting plate for the door check and the hook is prescribed if nothing else is noted. In case of doubt, please contact our technical customer service.

Manu- facturer	Type of door	Closing device		Mounting Plates	Approval	Manufacturer's declaration	V 1600 model
		Spring hinge	Overhead door closer				
<b>Domoferm</b>	all	x	x	prescribed		06 February 2015	V 1600 F
	LF 531	x	x	prescribed only for door check	Z-6.20-2058 Stand 12.10.2016	08 March 2017	V 1600, 50 N, adjustable
<b>Hörmann</b>	H8-5	x	x	prescribed	Z-6.20-2063 state 05.03.2015	27 April 2015	V 1600 F
	Quadro		x	prescribed	Z-6.20-1852 state 04.03.2011	27 April 2015	V 1600 F
	H3, H3-RS* <sup>1</sup>	x	x	prescribed only for door check	Z-6.20-1929 state 05.11.2014	19 May 2016	V 1600 F
	H3D, H3D-RS* <sup>1</sup>	x	x	prescribed only for door check	Z-6.20-1974 state 21.03.2013	19 May 2016	V 1600 F
	H16, H16-RS* <sup>1</sup>	x	x	prescribed only for door check	Z-6.20-2010 state 02.06.2014	19 May 2016	V 1600 F
	H6, H6-RS* <sup>1</sup>	x	x	prescribed only for door check	Z-6.20-2047 state 11.02.2015	19 May 2016	V 1600 F
	H3 OD, H3 OD- RS* <sup>1</sup>	x	x	prescribed only for door check	Z-6.20-2203 state 16.12.2014	19 May 2016	V 1600 F

Manufacturer	Type of door	Closing device		Mounting Plates	Approval	Manufacturer's declaration	V 1600 model
		Spring hinge	Overhead door closer				
	H16 OD, H16 OD-RS*1	x	x	prescribed only for door check	Z-6.20-2234 state 19.02.2015	19 May 2016	V 1600 F
	H3 (for exterior walls)	x	x	prescribed only for door check	Z-6.21-2186 state 05.04.2016	19 May 2016	V 1600 F
<b>Hörmann</b>	RS55*1	x	x	prescribed only for door check	P14-000005-PR01, P14-000005-PR02 state 01.04.2014	19 September 2016	V 1600 F
	HE 311, T 30-1-(RS)-FSA*2		x	not required	Z-6.20-1898 state 02.10.2016	11 October 2016	V 1600 F
	HE 321, T 30-2-(RS)-FSA*2		x	not required	Z-6.20-1898 state 02.10.2016	11 October 2016	V 1600 F
	HE 312, T 30-1-FSA*2 (for exterior walls)		x	not required	Z-6.21-2239 state 17.01.2015	11 October 2016	V 1600 F
	HE 322, T 30-2-FSA*2 (for exterior walls)		x	not required	Z-6.21-2239 state 17.01.2015	11 October 2016	V 1600 F
	HE 611, T 60-1-(RS)-FSA*2		x	not required	Z-6.20-1839 state 14.01.2015	11 October 2016	V 1600 F
	HE 621, T 60-2-(RS)-FSA*2		x	not required	Z-6.20-1839 state 14.01.2015	11 October 2016	V 1600 F
	HE 911, T 90-1-(RS)-FSA*2		x	not required	Z-6.20-1966 state 21.12.2012	11 October 2016	V 1600 F
	HE 921, T 90-2-(RS)-FSA*2		x	not required	Z-6.20-1966 state 21.12.2012	11 October 2016	V 1600 F
	A/RS 150, RS-1-door*2		x	not required	P-3545/787/14-MPA BS, state 01.04.2014	11 October 2016	V 1600 F

Manufacturer	Type of door	Closing device		Mounting Plates	Approval	Manufacturer's declaration	V 1600 model
		Spring hinge	Overhead door closer				
	A/RS 250, RS-2-door* <sup>2</sup>		x	not required	P-3545/787/14-MPA BS, state 01.04.2014	11 October 2016	V 1600 F
	A/RS 100, RS-1-door* <sup>2</sup>		x	not required	P-3609/851/14-MPA BS, state 01.07.2014	11 October 2016	V 1600 F
<b>Hörmann</b>	A/RS 200, RS-2-door* <sup>2</sup>		x	not required	P-3609/851/14-MPA BS, state 01.07.2014	11 October 2016	V 1600 F
<b>Novoform Rießinger</b>	„NovoPorta Premio“ T 30-1-FSA	x	x	prescribed		24 Nov. 2014	V 1600 F
	„NovoPorta Premio“ T 30-1-RS-FSA		x	prescribed		24 November 2014	V 1600 F
	H8-5	x	x	prescribed	Z-6.20-2151 state 20.10.2016		V 1600 F
<b>DMW Schwarze</b>	Schwarze-S20 Schwarze-S1 Schwarze-FE	x	x	prescribed		12 November 2015	V 1600 F
<b>Schüco</b>	ADS 80 FR 30* <sup>3</sup>		x	depends on mounting position	Z-6.20-1888 state 17.09.2016		V 1600 F
<b>Teckentrup</b>	all	x	x	prescribed		10 October 2014	V 1600 F

\*<sup>1</sup> max. modular dimension 1250 x 2500 mm. In the case of doors with two leafs and all other not mentioned fire doors, please contact the DICTATOR technical customer service.

\*<sup>2</sup> max. modular dimension 1250 x 2500 mm, max. weight of door leaf 200 kg. In the case of doors with two leafs and all other not mentioned fire doors, please contact the DICTATOR technical customer service.

\*<sup>3</sup> In the case of doors with two leafs and all other not mentioned fire doors, please contact the DICTATOR technical customer service.

## You have questions?

We would be pleased to help you. Please contact us!

